



**SK9000UB**

## **ULTRA SIMPLEKEY BASE MODULE, BLACK**



SimpleKey Basic access control module for Ultra entrance panel, colour black RAL9005, compatible with all systems. Equipped with RFID reader for activation of an opening using keys or Comelit cards. Can store up to 1500 electronic keys. Anodised aluminium alloy coating. Dimensions (L x H x D): 100 x 90 x 35 mm.

### **AWARDS**



**SK9000UB**

**ULTRA SIMPLEKEY BASE MODULE, BLACK**

**GENERAL DATA**

Type	Modular
Height (mm)	90
Width (mm)	100
Depth (mm)	35
Product weight (g)	350
Type of finishing materials	PMMA, Anodized aluminum
Product color	Black RAL9005
Flush-mounted	Yes, with a dedicated accessory
Wall-mounted	Yes, with a dedicated accessory

**COMPATIBLE SYSTEMS**

Audio/video Simplebus 2 with power supply art. 4888C	Yes
Audio/video Simplebus 2 with power supply art. 1210/1210A	Yes
Audio Simplebus 1	Yes
ViP	Yes

**ELECTRICAL CHARACTERISTICS**

Type of power supply	External power supply
Supply voltage	12÷33VDC / 12÷24VAC
Absorption in stand-by (W)	1.6
Maximum absorption (W)	7.2

**HARDWARE FEATURES**

Clamps	V+ V- D+ D- NC C NO PB G
Removable terminals	Yes
Number of inputs (n°)	1
Number of outputs (n°)	1
Type of outputs	Relay (C-NO-NC, 5A@12÷24 VAC/VDC)



**SK9000UB**

**ULTRA SIMPLEKEY BASE MODULE, BLACK**

**HARDWARE FEATURES**

Integrated proximity reader	RFID Mifare Classic
Communication ports	RS485

**ENVIRONMENTAL AND COMPLIANCE FEATURES**

IP protection rating	IP65
Vandal Resistant rating (IK code)	IK08
Operating temperature (°C)	-25 ÷ 55
Operating humidity (RH max) (%)	25 ÷ 95
Environmental class	IV
CE certifications	RoHS II - 2011/65/UE (EN IEC 63000:2018), RED 2014/53/UE (EN 62311:2008, EN 62368-1:2014, EN 61000-6-1:2007, EN 61000-6-3:2007 + A1:2011, ETSI EN 301 489-1 V2.2.0, ETSI EN 301 489-17 V3.2.0, ETSI EN 300 328 V2.1.1)

**MAIN FUNCTIONS**

Door opener	Yes
Number of auxiliary relays (n°)	1
Input for local door release button	Yes
Access control via proximity reader	Yes
Number of storable proximity keys	1500
Visual indications of system status	Yes