



SL-ZSK 50(80)A-2N m.TRE-S



de	Originalbetriebsanleitung	fi	Alkuperäiset ohjeet
en	Original instruction	no	Original bruksanvisning
fr	Notice originale	da	Original brugsanvisning
nl	Oorspronkelijke gebruiksaanwijzing	pl	Instrukcja oryginalną
it	Istruzioni originali	hu	Eredeti használati utasítás
es	Manual original	sv	Bruksanvisning i original
pt	Manual original		

Änderungen, Irrtümer und Druckfehler vorbehalten.

EN 60903
(VDE 0682-311)

AC 1000V
EN IEC 60900

i SL-ZSK 50(80)A-2N m.TRE-S

1/3/4/6/7/
9/10/12
18-22mm

Md = 3,0 Nm

2/5/8/11 Md = 0,5 Nm

12-18mm

rigid solid ✓

rigid stranded ✓

flexible without ferrule ✗

flexible with ferrule ✓

Sicherheitshinweis:
Schalten Sie die Anlage spannungsfrei

Montage
Zähleranschluss-
klemme
(Bild 1 - 4)

Montage
Smartmeter /
Energiezähler
(Bild 5 - 9)



